



**AURANGABAD MUNICIPAL CORPORATION**  
**FIRE BRIGADE**  
**TELEPHONE NO-2334000-40FAX No-2331444**

Outward No:AMC/FIRE / 355 /2020

Date 16 / 09/2020

To,  
President, Vardan Foundation's,  
Chaitanya Valley International School,  
Gut No. 224(P), At. Karmad Ta & Dist. Aurangabad.

Sub;- Fire NOC Renwal is issued to the President, Vardan Foundation's, Chaitanya Valley International School, Gut No. 224(P), At. Karmad Ta & Dist. A.bad.

Ref;- 1) Your letter dated 28/03/2019 2) Final Noc on date 17/08/2019  
3) Your Letter dated 16/09/2020 4) CFO Inspection on date 16/09/2020


With Reference to the above subject Fire NOC Renwal is issued to the President, Vardan Foundation's, Chaitanya Valley International School, Gut No. 224(P), At. Karmad Ta & Dist. Aurangabad. Plot area 8000.00 sq. meter.

Sr. No	Name of Building	Height of Building	Bild No.	No of floors	Total Area of Plot	Built/up area	Fire Fund	NOC Fees
1	School Building	10.28 Mtr.	1	P+2 Floors	8000.00 Sq.Mtr.	4011.68 Sq.Mtr.	25000	10000

Following Fire prevention and Fire protection & Fire Fighting measures subject to the is **School Building** is provided.

1. Open space all around the building is provided for free movements of fire tender which will carry 25 tons weight capacity.
2. Over head fire water tank of 10000 ltrs capacity with Booster Pump-03 HP-01 Nos is provided.
3. Fire service in let 2 ways incoming is provided.
4. 01 Nos. Down Commer having hydrant point on all floors with Hose Reel is provided.
5. 07 Nos. Hose reel of 100 feet on all out lets is provided.
6. Fire Extinguisher of Water CO2 -09 Ltr.- 09 Nis. Co2 -4.5 Kg -01 Nos of suitable capacity is provided.
7. Main Staircase 2.0 mtr. & Separate Fire Escape staircase 1.5 mtr. is provided.
8. This Certificate shall be treated valid for a period of one year from the date of issue of Fire Noc.
9. Fire Noc is valide for one year & Noc should be renewed each year.


As per BPMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention&Life safety Measures Act 2006 Reference to above subject Fire NOC Renwal is issued to the President, Vardan Foundation's, Chaitanya Valley International School, Gut No. 224(P), At. Karmad Ta & Dist. Aurangabad.

  
16-9-2020  
Chief Fire Officer  
Fire Brigade  
Municipal Corporation Aurangabad

Copy to:- A D.T.P AMC, Aurangabad.

  
SECRETARY

Chaitanya Valley International School  
Karmad Ta Dist Aurangabad

  
PRINCIPAL  
CHAITANYA VALLEY  
International School,  
Pimpri Road Karmad,